



ENERGY STAR CERTIFIED

Uninterruptible Power Supplies

EXR Series - EXR1500RT2U : 90000967

Specifications

| | |
|--|--|
| Brand Name: | EXR Series |
| Model Name: | EXR1500RT2U |
| Model Number: | 90000967 |
| Power Conversion Mechanism: | Static |
| Minimum Configuration Tested Model Number: | EXR1500RT2UNC |
| Active Output Power Rating Minimum Configuration (W): | 1350 |
| Apparent Output Power Rating Minimum Configuration (VA): | 1500 |
| Maximum Configuration Tested Model Number: | N/A |
| Topology (ac): | Passive Standby |
| Topology and Product Type Combined: | Alternating Current (ac) - Offline (VFD) |
| Application: | Consumer,Commercial |
| Rated Input Voltage (V rms): | 78-164 |
| Rated Input Frequency (Hz): | 44-66 |
| Rated Output Voltage (V): | 97-141 |
| Rated Output Frequency (Hz): | 44-66 |
| Rack Mountable: | Yes |
| Rack Mount Height (U): | 2 |
| Height (mm): | 89 |
| Width (mm): | 556 |
| Depth (mm): | 482 |
| Total Number of Outlets: | 8 |
| Number of Battery Backup and Surge Protected Outlets: | 8 |
| Number of Surge Protected Only Outlets: | 0 |
| Normal Mode(s) Input Dependency Characteristic (ac): | Voltage and Frequency Dependent |
| Modular UPS: | Yes |
| Number of Normal Modes: | Single-normal-mode |
| Default Normal Mode (ac): | Voltage and Frequency Dependent |
| Test Input Voltage (V rms): | 120 |
| Test Input Frequency (Hz): | 60 |

| | |
|--|---|
| Test Output Voltage (V): | 120 |
| Test Output Frequency (Hz): | 60 |
| Total Input Power in W at 0% Load Min Config Lowest Dependency (ac): | 18.8 |
| Efficiency at 25% Load Min Config Lowest Dependency (ac): | 97.6 |
| Efficiency at 50% Load Min Config Lowest Dependency (ac): | 98.4 |
| Efficiency at 75% Load Min Config Lowest Dependency (ac): | 98.4 |
| Efficiency at 100% Load Min Config Lowest Dependency (ac): | 98.3 |
| Weighted Efficiency Calc Min Config Lowest Dependency: | 98.4 |
| Efficiency (%): | 98.4 |
| Modular UPS Module Tested Model Number: | N/A |
| Energy Storage Mechanism: | Other |
| Energy Storage System Technology: | Other |
| Energy Storage System Configuration: | Integral |
| Energy Storage System Removable to Another Room: | Yes |
| Energy Storage System Runtime at 100% Load (min.): | 3 |
| Energy Storage System Runtime at 50% Load (min.): | 10 |
| Energy Storage System Warranty (yrs): | 3 |
| Energy Storage System Information URL: | N/A |
| Network Connections Available: | Serial Port,Other,USB Port,Ethernet |
| Communication Protocols: | HTTP,Other,SNMP (v1, 2 or 3) |
| Communication Protocol Other: | USB: HID power device protocol; Serial: Other |
| Manufacturer Take Back Program: | Yes |
| Model Web Page URL: | https://minutemanups.com/ |
| Test Method Guidelines: | N/A |
| Date Available on Market: | 2021-01-01 |
| Date Certified: | 2020-12-01 |
| Markets: | United States, Taiwan, Japan, Canada |
| ENERGY STAR Certified: | Yes |

Additional Model Information

Captured On:
04/15/2021